



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121257, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, January 18, 2013

Partial Correction  
1 MISC

FOLLOWING COMPONENTS OF PASSENGER ELEVATOR FRONTS OK TO COVER WHEN READY :

1ST FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED;

2ND FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

3RD FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED;

4TH FLOOR: 2ND FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

5TH FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED

Partial Correction  
2 MISC

FOLLOWING COMPONENTS OF 1ST FLOOR FREIGHT ELEVATOR SHAFT OK TO COVER WHEN READY: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB

Partial Correction  
3 MISC

FOLLOWING COMPONENTS OF FREIGHT ELEVATOR FRONTS

OK TO COVER WHEN READY:

2ND FLOOR THROUGH 5TH FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB

Partial Correction  
4 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED WALL @ 4F021 SW: ONE LAYER OF 5/8" TYPE X GWB

**In-wall Inspection**

John Borns

Partial

Friday, January 18, 2013

Partial Correction  
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 3F012; 4F017 THRU 020; 024 THRU 019; 061; 061A THRU 065; 066 thru 070; 072; 045; 075; 042; 074; 075; 076; 016; 034 THRU 041; 031; 032; 033; 016 N END; 4F020 BOTH FACES EXCEPT SE WHERE LATER TO INTERFACE W/ BLDG 100; 022 OUTSIDE FACE WHERE REMOVED FOR MODIFICATIONS AND REPLACED ; 071A; DUPLEX EMERGENCY CIRCUIT ELECT RECEPT ADDED TO HEADWALL @ IC UNITS 4F061 THROUGH 076; 071 SE; PASSENGER ELEVATOR ENTRANCES AT 2ND & 4TH FLOORS; WALL + DOOR FRAME @ 4F021 SW;

**Rated Assembly Inspection**

John Borns

Partial

Friday, January 18, 2013

Partial Correction  
1 MISC

FOLLOWING COMPONENTS OF PASSENGER ELEVATOR FRONTS OK TO COVER WHEN READY :

1ST FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED;

2ND FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

3RD FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED;

4TH FLOOR: 2ND FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

5TH FLOOR: FRAMING, LINER BOARD + FIRE CAULK; ONE LAYER 5/8" TYPE X GWB FIRE-CAULKED

Partial Correction  
2 MISC

FOLLOWING COMPONENTS OF 1ST FLOOR FREIGHT ELEVATOR SHAFT OK TO COVER WHEN READY: FRAMING, LINER BOARD +

Partial Correction  
3 MISC

FIRE CAULK; ONE LAYER 5/8" TYPE X GWB

FOLLOWING COMPONENTS OF FREIGHT ELEVATOR FRONTS  
OK TO COVER WHEN READY:  
2ND FLOOR THROUGH 5TH FLOOR: FRAMING, LINER BOARD +  
FIRE CAULK; ONE LAYER 5/8" TYPE X GWB

**Comments:**