



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, January 22, 2013

Partial Correction
1 MISC

FOLLOWING COMPONENTS OF PASSENGER ELEVATOR
FRONTS OK TO COVER WHEN READY :

1ST FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO
LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

2ND FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO
LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

3RD FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO
LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

4TH FLOOR: 2ND FLOOR: FRAMING, LINER BOARD + FIRE
CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD &
FINISH

5TH FLOOR: FRAMING, LINER BOARD + FIRE CAULK; TWO
LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FINISH

Partial Correction
2 MISC

FOLLOWING COMPONENTS OF 1ST FLOOR FREIGHT ELEVATOR
SHAFT OK TO COVER WHEN READY: FRAMING, LINER BOARD +
FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD
& FINISH

Partial Correction

3 MISC

FOLLOWING COMPONENTS OF FREIGHT ELEVATOR FRONTS
OK TO COVER WHEN READY:
2ND FLOOR THROUGH 5TH FLOOR: FRAMING, LINER BOARD +
FIRE CAULK; TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD
& FINISH

Partial Correction

4 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF
RATED WALL @ 4F021 SW: TWO LAYERS 5/8" TYPE X GWB OK
TO TAPE, MUD & FINISH

Comments: