



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20122126, Building Permit - Residential
Address: 301 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	John Borns	Passed	Wednesday, January 23, 2013

Electrical Service Inspection - Residential	John Borns	Partial	Wednesday, January 23, 2013
--	------------	---------	-----------------------------

Corrective Action Required
2 MISC

NEC 250-64: USE NON-REVERSIBLE CONNECTORS ON
GROUNDING ELECTRODE CONDUCTOR SPLICES. DO NOT
COVER SPLICE BEFORE RE-INSPECTION.

**Comments: HOMEOWNER STATES M.G.E. ACTIVATED GAS SERVICE WITHOUT
RELEASE FROM L.S. CODES.**