



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130008, Building Permit - Commercial
Address: 471 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Failed	Thursday, January 24, 2013

Corrective Action Required
1 MISC

1. SECURE MC WITHIN 12" OF BOX.
2. SOUTH WEST OFFICE - SUPPORT 2X4 LIGHT IN CEILING.

Comments: