



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20122713, Building Permit - Commercial  
Address: 3680 NE AKIN DR, Unit:130, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Passed	Tuesday, January 29, 2013

### Corrective Action Required

1	MISC	-INSTALL BLOCKING FOR GRAB BARS -SECURE PEX AT MID-WALL HEIGHT -PROTECT PLUMBING AT BOTTOM WALL PLATE WOMAN RESTRM.
---	------	--

### Comments: