



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121257, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Friday, February 01, 2013

Partial Correction  
1 MISC

ELEVATORS AT 120 SURGICENTER INSTALLED UNDER THIS PERMIT APPROVED BY STATE OF MISSOURI INSPECTOR 12/13/12.

Partial Correction  
2 MISC

4TH FLOOR FINAL: OK TO SET UP FOR OPERATION

REQUIRED FOR FULL OCCUPANCY:

- STATE ELEVATOR INSPECTION APPROVAL
- INSTALLATION OF BACKFLOW PREVENTION DEVICES AT EQUIPMENT PIPED WITH POTABLE WATER
- FINAL WORK IN PROGRESS AT NEW-TO-EXISTING INTERFACES AS DESCRIBED IN ADAM WIEDERHOLT 1/30/2013 E-MAIL MEMO

**Comments:**