



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121767, Building Permit - Commercial
Address: 5000 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Tuesday, February 05, 2013

Corrective Action Required

1	MISC	-PROTECT DVW PVC WHERE INSTALLED WITHIN 1.5" OF STUD/TRACK SURFACE @ RESTROOM AREA -INSTALL SHEAR WALL TIE DOWNS PER PLAN; SCREW DOUBLE STUD TOGETHER PER S2 DETAIL -INSTALL EM CIRCUIT PER PLAN
---	------	--

Comments: