



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20121257
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Inspected On: Friday, February 08, 2013
Inspected By: John BornsJohn Borns
Expiration Date: 4/25/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Friday, February 08, 2013

Partial Correction:
2 MISC 4TH FLOOR FINAL: OK FOR OCCUPANCY

REQUIRED FOR FULL OCCUPANCY:
- INSTALLATION OF BACKFLOW PREVENTION DEVICES AT EQUIPMENT PIPED WITH POTABLE WATER
- FINAL WORK IN PROGRESS AT NEW-TO-EXISTING INTERFACES AS DESCRIBED IN ADAM WIEDERHOLT 1/30/2013 E-MAIL MEMO

Above Ceiling Inspection	John Borns	Partial	Friday, February 08, 2013
---------------------------------	------------	---------	---------------------------

Partial Correction:
1 MISC OK TO COVER WHEN READY GWB CEILING FRAMING AND

ABOVE-CEILING SYSTEMS AT: 3F012; SHOWERS AT 061-065;
NURSE WORK STATIONS IN CORRIDOR 031; SOFFITS @
INNER ARC OF CORRIDORS 4F016, 031, 034/035, 041; ARC
SOFFITS @ ENDS OF CORRIDORS 4F031/034 & 041;
TRIANGULAR SEGMENT IN CORR 021 S OF SE CORNER OF
FREIGHT ELEVATOR SHAFT; ELEVATOR CORRIDOR 001
EXCEPT WHERE STRUCTURAL EXPANSION JOINT REQUIRES
FIRE PROTECTION AND ELECT CABLE TRAY REQUIRES
"PILLOWS".

Partial Correction:

2 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 4F015;
016; 017; 018; 022; 023 THRU 030; 031; 034; 035; 036; 037; 038;
039; 040; 041; 042; 043; 061/061A THRU 064/064A; 065/065A;
065B THRU 070/070A; 071/071A; 072/072A; 073/073A; 074/074A;
075/075A; 076/076A;

Comments: