



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122034, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:T, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, February 14, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: PERIMETER WALLS AFTER SPRINKLER F.P. PIPE @ EAST WALL IS PROPERLY SECURED; SHOE STORAGE BOTH FACES; WING WALL PER ELEVATION 5/A-4.1 BOTH FACES; **N-S WALL AT REAR PASSAGEWAY WHERE ELECTRICAL PANELS ARE TO BE MOUNTED;**

Comments: