



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20122034, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:T, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Passed	Tuesday, February 19, 2013

<b>In-wall Inspection</b>	John Borns	Partial	Tuesday, February 19, 2013
---------------------------	------------	---------	----------------------------

Partial Correction

1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: PERIMETER WALLS AFTER SPRINKLER F.P. PIPE @ EAST WALL IS PROPERLY SECURED; SHOE STORAGE BOTH FACES; WING WALL PER ELEVATION 5/A-4.1 BOTH FACES; N-S WALL AT REAR PASSAGEWAY WHERE ELECTRICAL PANELS ARE TO BE MOUNTED; **SALES AREA AND ALL REMAINING EXCEPT REAR (EAST) SPACES;**

**Comments: OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT; ALSO SECURITY ANTENNAE NEAR ENTRANCE**