



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|----------------------------------|------------|----------|-----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rated Assembly Inspection | John Borns | Partial | Thursday, February 21, 2013 |

Corrective Action Required
3 MISC

OK TO COVER WHEN READY GWB AT UL-RATED WALLS AT
1F090: W WALL FROM B/6 TO SOUTH 1ST LAYER 5/8" TYPE X
GWB;

Comments: