



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20122034, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:T, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:               | Inspector: | Outcome: | Date:                     |
|---------------------------|------------|----------|---------------------------|
| <b>In-wall Inspection</b> | John Borns | Partial  | Monday, February 25, 2013 |

Partial Correction

1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: PERIMETER WALLS AFTER SPRINKLER F.P. PIPE @ EAST WALL IS PROPERLY SECURED; SHOE STORAGE BOTH FACES; WING WALL PER ELEVATION 5/A-4.1 BOTH FACES; N-S WALL AT REAR PASSAGEWAY WHERE ELECTRICAL PANELS ARE TO BE MOUNTED; SALES AREA AND ALL REMAINING EXCEPT REAR (EAST) SPACES; FITTING ROOM AREA;

|                                  |            |        |                           |
|----------------------------------|------------|--------|---------------------------|
| <b>Rated Assembly Inspection</b> | John Borns | Passed | Monday, February 25, 2013 |
|----------------------------------|------------|--------|---------------------------|

**Comments: AT CORRIDOR WALL TENANT FACE AT RESTROOM AREA OK TO TAPE, MUD, AND FIRE-SEAL 5/8" TYPE X GWB.**