



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Friday, March 01, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY SCH 40 6" PVC CONDUIT UNDER GRADE BEAM @ (DD.5)/(12) AND SWEEP UP ABOVE FLOOR ELEVATION INSIDE BUILDING;

Partial Correction
2 MISC

OK TO COVER WHEN READY UNDER-SLAB SCH 40 2-1/2" PVC CONDUIT FROM (H)/(9) TO 18' NW;

Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, March 01, 2013
---	------------	---------	------------------------

Partial Correction
1 MISC

OK TO COVER WHEN READY UNDER-SLAB C.I. DWV PIPING AT FOLLOWING LOCATIONS: ALL FROM (4) WEST TO (9);

Comments: