



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121257, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, March 01, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY GWB AT UL-RATED WALLS AT 1F090: W WALL FROM B/6 TO SOUTH 2 LAYERS 5/8" TYPE X GWB; NE WALL 2 LAYERS 5/8" TYPE X GWB; **IN-FILL @ E WALL 2 LAYERS 5/8" TYPE X GWB**

NOTE: CHECK BUMP-OUT AT INTERSECTION OF NE WALL & IN-FILL @ E WALL TO ENSURE 2-LAYER FIRE INTEGRITY.

Comments: