

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX: 816-969-1201

Temporary Certificate of Occupancy

Permit #: Address: Inspected On: Inspected By: Expiration Date:

PRCOM20122713 3680 NE AKIN DR, Unit:130, LEES SUMMIT, MO 64064 Monday, March 04, 2013 Khanh Nguyen 3/25/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Monday, March 04, 2013

Corrective Action Required:

MISC

1

-FIRE DEPT. APPROVAL -NO SMOKING SIGNAGE AT ENTRY DOOR -PAINT EXTERIOR GAS PIPING -ADJUST RESTROOM DOORS TO 5 LBS OR LESS -HANDRAIL AT STAIR AND RAMP SHALL BE PER CODE-CONTINUOUS HANDRAIL WITH HORIZONTAL EXTENSION AT ENDS AND RETURNED TO WALL. -KIDS' ROOM ADA RESTROOM PER PLAN

Comments: