



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130270, Building Permit - Commercial
Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, March 08, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY EXTERIOR WALL DENSGLAS
FIREGUARD SHEATHING AT FOLLOWING LOCATIONS: GROUND
FLOOR NORTH, SOUTH, EAST, & WEST WALLS;

Comments: