



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122034, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:T, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Passed	Friday, March 08, 2013

Gas Piping Inspection - Commercial	John Borns	Partial	Friday, March 08, 2013
---	------------	---------	------------------------

Corrective Action Required
1 MISC

IFGC 404.8: EXPOSED METALLIC PIPING MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS.

Comments: GAS PIPING PRESSURE TEST HELD STEADY AT >= 10 PSI FOR >=10 MIN. RELEASE GAS SERVICE.