



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20122587, Building Permit - Residential  
Address: 1321 NE COUNTRY LN, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, March 08, 2013

Corrective Action Required  
1 MISC

-FIREBLOCKING: FB B-VENT/DUCT/PLUMBING CHASE AT  
PANTRY FROM JOIST SPACE  
-CONSECUTIVE OVERBORED JOISTS BY 3" PVC ABOVE LIVING  
RM. HAVE ENGINEER ADDRESS REINFORCEMENT OR  
APPROVE AS IS.  
-INSTALL H-CLIPS: REAR NE BED (A01); ABOVE BATH/CLOSET  
WALL (A13, A14, A15) \*\*READ NOTE 9 OF TRUSS PAGE. H-CLIPS  
REQUIRED AT JOINT 1 AND 10, NOT JUST JOINT 1.

\*OK TO INSULATE. NO ROCK

**Comments:**