



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130027, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086  
Unit: 120, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, March 13, 2013

Partial Correction  
1 MISC

OK TO COVER WHEN READY 25' OF SIX 4" PVC ELECT  
CONDUITS + TWO RUNS OF 2" CONDUIT -- ALL INSIDE WEST  
WALL ADJACENT TO BUNKER UNDER CONSTRUCTION;

<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, March 13, 2013
--------------------------------------	------------	---------	---------------------------

Partial Correction  
1 MISC

OK TO APPLY 2ND LAYER OF GWB @ N&NE WALLS OF 1F150 &  
1F151;

**Comments:**