



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121257, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, March 15, 2013

Partial Correction  
1 MISC

OK TO COVER WHEN READY GWB AT UL-RATED WALLS AT 1F090: W WALL FROM B/6 TO SOUTH 2 LAYERS 5/8" TYPE X GWB; NE WALL 2 LAYERS 5/8" TYPE X GWB; IN-FILL @ E WALL 2 LAYERS 5/8" TYPE X GWB; **N,W,S WALLS BOTH FACES SPACE 1F151A -- NOTE: SPACE COMMUNICATES WITH OTHER SPACES VIA OVERHEAD CONCRETE STRUCTURE EXPANSION JOINT -- APPROVABLE CLOSURE REQUIRED;**

<b>Above Ceiling Inspection</b>	John Borns	Partial	Friday, March 15, 2013
---------------------------------	------------	---------	------------------------

Partial Correction  
1 MISC

OK TO COVER WHEN READY GWB CEILING FRAMING AND ABOVE-CEILING SYSTEMS AT: 3F012; SHOWERS AT 061-065; NURSE WORK STATIONS IN CORRIDOR 031; SOFFITS @ INNER ARC OF CORRIDORS 4F016, 031, 034/035, 041; ARC SOFFITS @ ENDS OF CORRIDORS 4F031/034 & 041; TRIANGULAR SEGMENT IN CORR 021 S OF SE CORNER OF FREIGHT ELEVATOR SHAFT; ELEVATOR CORRIDOR 001 EXCEPT WHERE STRUCTURAL EXPANSION JOINT REQUIRES FIRE PROTECTION AND ELECT CABLE TRAY REQUIRES "PILLOWS".

Partial Correction  
2 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING +

ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 4F015; 016;  
017; 018; 022; 023 THRU 030; 031; 034; 035; 036; 037; 038; 039;  
040; 041; 042; 043; 061/061A THRU 064/064A; 065/065A; 065B  
THRU 070/070A; 071/071A; 072/072A; 073/073A; 074/074A;  
075/075A; 076/076A; **1F007**

**Comments:**