



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O. BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130108, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Failed	Tuesday, March 19, 2013

Corrective Action Required
1 MISC

GROUND JUMPER FROM LOAD SIDE DISCONNECT TO TROUGH ABOVE: CONDUIT CONNECTION TO DISCONNECT ENCLOSURE NOT TIGHTENED.

Corrective Action Required
2 MISC

MARK SUITE ADDRESS ON SERVICE METER ENCLOSURE -- EITHER TEMPORARY (MARKER OK FOR TEMPORARY) OR PERMANENT (STICKER OR PLACARD) BEFORE SERVICE IS RELEASED. ADDRESS ON CARDBOARD BLANK-OFF WILL NOT REMAIN AFTER METER IS SET.

In-wall Inspection	John Borns	Passed	Tuesday, March 19, 2013
---------------------------	------------	--------	-------------------------

Comments: OK TO COVER WALLS AND PARTITIONS WHEN READY.