



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121767, Building Permit - Commercial
Address: 5000 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Tuesday, March 19, 2013

Corrective Action Required
1 MISC

-TAPE ALL DUCT JOINTS
-AT SOUTH EXT. WALL-MATERIALS WITHIN PLENUM SHALL BE
NON-COMBUSTIBLE OR SHALL HAVE A FLAME SPREAD INDEX
OF NO MORE THAN 25 AND A SMOKE DEVELOP INDEX OF NO
MORE THAN 50

Sprinkler - Hydrostatic Test	Joe Dir	Passed	Tuesday, March 19, 2013
---	---------	--------	-------------------------

Comments: