



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130108, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Wednesday, March 20, 2013

Comments: RELEASE ELECTRICAL SERVICE CONTINGENT ON FOLLOWING: BEFORE SERVICE IS ACTIVATED RE-TERMINATE GROUND CONDUCTORS IN LOAD SIDE DISCONNECT, ENSURING ALL STRANDS ARE INSERTED UNDER LUG SCREW. WILL BE RE-INSPECTED LATER.