



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086110 NE SAINT LUKES
BLVD, Unit:120, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mike Copeland	Partial	Tuesday, March 26, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY 25' OF SIX 4" PVC ELECT
CONDUITS + TWO RUNS OF 2" CONDUIT -- ALL INSIDE WEST
WALL ADJACENT TO BUNKER UNDER CONSTRUCTION;
ALL CONDUIT FOR BUILDING F UNDERSLAB IN CONTROL ROOM
APPROVED

Comments: