



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20122126, Building Permit - Residential
Address: 301 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Passed	Thursday, March 28, 2013

Comments: COMBUSTION AIR FOR WATER HEATER MAY BE PULLED FROM NEW FAMILY ROOM. DOOR TO BEDROOM MUST BE SEALED AND SELF-CLOSING.