

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLAN REVIEW CONDITIONS

April 01, 2013

MID AMERICA CONTRACTORS, INC
1400 IRON
NORTH KANSAS CITY, MO 64116

Permit No: PRCOM20130437
Project Title: KANSAS CITY NEUROLOGY
Project Address: 2000 SE BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 60420990900000000
Location: HCA MIDWEST, LOTS 1A & 1B---LOT 1A
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: BUSINESS
Description: CONSTRUCT WALL TO SEPARATE CONFERENCE ROOM INTO TWO OFFICES

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Michael Weisenborn

Approved

Fire Plan Review

Reviewed By: Brian Austerman

Approved with Conditions

1. Alterations to the existing sprinkler system may be required based on required after installation of the new wall. To be determined on inspection.

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

____ Approved to issue per the listed conditions.
____ Do not issue per the listed conditions.
____ Approved to construct foundation only per the listed conditions.
____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.