



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122034, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:T, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Not Ready	Monday, April 01, 2013

Corrective Action Required
1 MISC

COURTESY PRE-FINAL WALK-THROUGH OBSERVATIONS:

- RESTROOM MIRRORS 1/2" HIGH
- MEN'S RR W.C. 3-1/2" TOO FAR FROM WALL
- ELECT RECEPT COVER PLATES TO BE PLACED
- ONE ELECT RECEPT MIS-WIRED
- STICK ELECT C.B. LABELS TO PANEL FRONTS
- PLACE ELECT PANEL SCHEDULES
- EXTERIOR LIGHTED SIGN SUBJECT TO APPROVAL
- AFFIX "NO SMOKING" STICKER AT PUBLIC ENT DOOR

FINAL INSPECTION WILL INCLUDE, BUT WILL NOT BE LIMITED TO, THE ABOVE ISSUES.

Gas Piping Inspection - Commercial	John Borns	Passed	Monday, April 01, 2013
---	------------	--------	------------------------

Comments: