



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121010, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	John Borns	Partial	Tuesday, April 02, 2013

Partial Correction  
1 MISC

SHOP WELDS OF GREASE DUCTS LIGHT TESTED AFTER DELIVERY TO JOBSITE. ALL OK EXCEPT THREE PINHOLES FOUND NEAR CONNECTION FLANGES; EACH HOLE WAS MARKED TO BE SPOT-WELDED LATER AS SECTIONS ARE INSTALLED AND WELDED IN PLACE.

Partial Correction  
2 MISC

FIELD WELDS OF GREASE DUCTS LIGHT TESTED OK: DUCTWORK FOR EFA-22 AT 5TH FLOOR EXCEPT FLANGE CONNECTION 4' AFF TO BE CONNECTED LATER WITH DUCT FROM BELOW; **DUCTWORK FOR EFA-24 AT 5TH FLOOR EXCEPT FLANGE CONNECTION 4' AFF TO BE CONNECTED LATER WITH DUCT FROM BELOW;**

**Comments:**