



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

220 SE GREEN ST.
P.O. BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20121405
Address: 178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Inspected On: Tuesday, April 02, 2013
Inspected By: John Borns
Expiration Date: 4/18/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Tuesday, April 02, 2013

Corrective Action Required:

1	MISC	RESOLVE ISSUES WITH FIRE DEPARTMENT AND WATER DEPARTMENT. eg, COMPLETE AND OBTAIN APPROVAL ON BACKFLOW PREVENTION EQUIPMENT PIT WEST OF BUILDING.
---	------	---

Corrective Action Required:

2	MISC	PROVIDE ELECTRICAL RECEPTACLE WITHIN 10 METERS OF RTU'S #11 AND #12
---	------	---

Corrective Action Required:

3	MISC	NO CLAMPS AT THREE SUPPORTS FOR GAS PIPING TO RTU #12
---	------	---

Corrective Action Required:

4	MISC	IN ELECT ROOM AT SIEMANS ELECT PANEL DESIGNATE CIRCUIT BREAKER POSITIONS ON PANEL FRONT 1 THRU 18.
---	------	--

Comments: