

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086110 NE SAINT LUKES

BLVD, Unit:120, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

John Borns Partial Wednesday, April 03, 2013 Underground

Electrical Inspection

- Commercial

John Borns Wednesday, April 03, 2013 Underground Partial

Electrical Inspection

- Commercial

Partial Correction

MISC OK TO COVER WHEN READY 25' OF SIX 4" PVC ELECT

> CONDUITS + TWO RUNS OF 2" CONDUIT -- ALL INSIDE WEST WALL ADJACENT TO BUNKER UNDER CONSTRUCTION:

ALL CONDUIT FOR BUILDING F UNDERSLAB IN CONTROL ROOM

APPROVED

Partial Correction

MISC OK TO COVER WHEN READY GROUND RING AROUND BUNKER

AND WAITING ROOM FOUNDATION: EAST, SOUTH AND WEST

SIDES:

Partial Wednesday, April 03, 2013 Underground John Borns

Electrical Inspection

- Commercial

Partial Correction

1 MISC

OK TO COVER WHEN READY GROUND RING AROUND BUNKER AND WAITING ROOM FOUNDATION: EAST, SOUTH, WEST AND NORTH SIDES EXCEPT FOR THREE LOCATIONS WHERE EXOTHERMIC WELD CONNECTIONS ARE TO BE COMPLETED AND INSPECTED BEFORE COVERING

Partial Correction 2 MISC

OK TO COVER WHEN READY 25' OF SIX 4" PVC ELECT CONDUITS + TWO RUNS OF 2" CONDUIT -- ALL INSIDE WEST WALL ADJACENT TO BUNKER UNDER CONSTRUCTION; ALL CONDUIT FOR BUILDING F UNDERSLAB IN CONTROL ROOM APPROVED

Comments: