



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130270, Building Permit - Commercial  
Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:                      | Inspector:   | Outcome: | Date:                  |
|----------------------------------|--------------|----------|------------------------|
| <b>Rated Assembly Inspection</b> | Khanh Nguyen | Partial  | Monday, April 08, 2013 |

Partial Correction  
1 MISC

OK TO COVER WHEN READY EXTERIOR WALL DENSGLAS  
FIREGUARD SHEATHING AT ENTIRE PERIMETER FULL HEIGHT

OK TO COVER 2ND FL NORTH, SOUTH, AND EAST EXTERIOR  
WALL

**Comments:**