



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130108, Building Permit - Commercial  
Address: 930 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Wednesday, April 10, 2013

Partial Correction  
1 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING +  
ABOVE-CEILING SYSTEMS EXCEPT @ SPACE 104

IPC - PROTECTION OF COPPER PIPING ADJACENT TO STEEL  
FRAMING MEMBERS: ISOLATE COPPER FROM DISSIMILAR  
METAL WITH NON-CONDUCTIVE MATERIAL -- SEE ABOVE  
SPACE 104

**Comments:**