



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Unit: 120, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Wednesday, April 10, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY GROUND RING AROUND BUNKER AND WAITING ROOM FOUNDATION: EAST, SOUTH, WEST AND NORTH SIDES EXCEPT FOR THREE LOCATIONS WHERE EXOTHERMIC WELD CONNECTIONS ARE TO BE COMPLETED AND INSPECTED BEFORE COVERING

Partial Correction
2 MISC

OK TO COVER WHEN READY 25' OF SIX 4" PVC ELECT CONDUITS + TWO RUNS OF 2" CONDUIT -- ALL INSIDE WEST WALL ADJACENT TO BUNKER UNDER CONSTRUCTION; ALL CONDUIT FOR BUILDING F UNDERSLAB IN CONTROL ROOM APPROVED

Partial Correction
3 MISC

MATERIAL AND WORKMANSHIP OK TO COVER WHEN READY UNDER-SLAB PVC ELECT CONDUITS + ONE 6" RACEWAY FOR PLUMBING LINES BELOW SPACES 1A127 & 1A128A

Partial Correction
4 MISC

OK TO COVER WHEN READY SCH 40 6" PVC CONDUIT UNDER GRADE BEAM @ (DD.5)/(12) AND SWEEP UP ABOVE FLOOR ELEVATION INSIDE BUILDING;

Partial Correction
5 MISC

OK TO COVER WHEN READY UNDER-SLAB SCH 40 2-1/2" PVC CONDUIT FROM (H)/(9) TO 18' NW;

Partial Correction
6 MISC

NO ISSUES WITH MATERIAL OR WORKMANSHIP AT
UNDER-SLAB PVC CONDUIT @ LINAC #1 & #2. OK TO COVER
WHEN READY

Underslab Plumbing John Borns
Inspection -
Commercial

Passed

Wednesday, April 10, 2013

Comments: UNDER-SLAB PVC ELECT CONDUIT AND C.I. DWV PIPING OK TO COVER
WHEN READY @ LINAC #1 & #2.