



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130263, Building Permit - Commercial
Address: 950 NW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Friday, April 12, 2013

Partial Correction

1 MISC

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL SYSTEMS AT: PERIMETER WALLS AFTER PLUMBING SHIELD PLATES ARE IN PLACE;

Corrective Action Required

2 MISC

SHIELD PLATES/BOCA PLATES NOT COMPLETED FOR PVC AND COPPER PIPING PENETRATIONS OF FRAMING. SOME GROMMETS NOT COMPLETED AT COPPER PIPING PENETRATIONS OF FRAMING.

Comments: