



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
110 NE SAINT LUKES BLVD, Unit:120, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, April 17, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY GROUND RING AROUND BUNKER AND WAITING ROOM FOUNDATION: EAST, SOUTH, WEST AND NORTH SIDES EXCEPT FOR THREE LOCATIONS WHERE EXOTHERMIC WELD CONNECTIONS ARE TO BE COMPLETED AND INSPECTED BEFORE COVERING

Partial Correction
2 MISC

OK TO COVER WHEN READY 25' OF SIX 4" PVC ELECT CONDUITS + TWO RUNS OF 2" CONDUIT -- ALL INSIDE WEST WALL ADJACENT TO BUNKER UNDER CONSTRUCTION; ALL CONDUIT FOR BUILDING F UNDERSLAB IN CONTROL ROOM APPROVED

Partial Correction
3 MISC

MATERIAL AND WORKMANSHIP OK TO COVER WHEN READY UNDER-SLAB PVC ELECT CONDUITS + ONE 6" RACEWAY FOR PLUMBING LINES BELOW SPACES 1A127 & 1A128A

Partial Correction
4 MISC

-GROUND RING WITH RODS AT 3 LOCATIONS

Rated Assembly Inspection	Khanh Nguyen	Partial	Wednesday, April 17, 2013
--------------------------------------	--------------	---------	---------------------------

Partial Correction
1 MISC

N&NE WALLS OF 1F150&1F151: OK TO APPLY 2ND LAYER OF
GWB; GWB PERIMETER FIRE-CAULKED & APPROVED TO
COVER

Partial Correction
2 MISC

FOLLOWING TYPE (P) WALL SECTIONS OK TO TOP OUT (6')
GWB ONE FACE FOR ADJACENT HVAC DUCT TO BE HUNG: ~24'
OF 1F007 EAST WALL ACROSS FROM PASSENGER
ELEVATORS; ~24' OF 1F100 NW WALL;

Partial Correction
3 MISC

RATED WALL DOG-LEGGED AT 1F151 WEST/NORTHWEST ONE
LAYER 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL
EXCEPT E-W LEG AT TOP 24" NEXT TO CONCRETE BEAM
NEEDS TO BE MORE SECURELY FASTENED TO FRAMING

*LID AT TOP OF 1F151 RATED WALL

In-wall Inspection

Khanh Nguyen Partial

Wednesday, April 17, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL
SYSTEMS AT FOLLOWING SPACES: ALL SPACES PLAN NORTH
OF CORRIDOR 1F007 EXCEPT 1F007A, 008A, 200, 201 AND 217;

1F138, 1F141, 1F141A, 1F142-145, 1F147; 109; 110; 113; 114; 115;
115; 116; 117; 1F007A; 1F200

Comments: