



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130151, Building Permit - Commercial
Address: 837 SW LEMANS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Failed	Friday, April 19, 2013

Corrective Action Required
1 MISC

- *POST OCCUPANT LOAD, POST ACCESSABLE SIGNAGE AT BATHROOMS.
- *INSTALL GRAB BARS IN REAR RESTROOM.
- *INSTALL VERTICAL GRAB BAR IN TWO MAIN RESTROOMS
- *RECEPTACLE AT REAR OF THE BAR SHOULD BE GFCI PROTECTED
- *RE-LABEL SERVICE PANEL ACCORDING TO ACTUAL WIRING.
- *COMPLETE KITCHEN EQUIPMENT AND OBTAIN HEALTH DEPARTMENT APPROVAL.

Comments: