



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20130709, Building Permit - Residential  
Address: 2710 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:  | Inspector: | Outcome: | Date:                  |
|--|------------|----------|------------------------|
| <b>Sewer Service<br/>Inspection -<br/>Residential</b>  | John Borns | Passed   | Monday, April 22, 2013 |
| <b>Final Plumbing<br/>Inspection -<br/>Residential</b> | John Borns | Passed   | Monday, April 22, 2013 |

**Comments: SEWER REPAIR APPROVED. OK TO COVER WHEN READY NEW 4" PVC FROM ENTRY TO HOUSE TO APPROX 15' SOUTH INCLUDING BI-DIRECTIONAL CLEANOUTS AND CONNECTION TO EXISTING 1-1/2" SINK DRAIN. CLOSE PERMIT AFTER ADDRESS IS CORRECTED TO 2110 VS 2710.**