



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130027, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086  
Unit: 120, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:               | Inspector: | Outcome: | Date:                   |
|---------------------------|------------|----------|-------------------------|
| <b>In-wall Inspection</b> | John Borns | Partial  | Tuesday, April 23, 2013 |

Partial Correction  
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: ALL SPACES PLAN NORTH OF CORRIDOR 1F007 EXCEPT 008A, 201 AND 217; 1F138, 1F141, 1F141A, 1F142-145, 1F147; 109; 110; 113; 114; 115; 116; 117; 1F007A; 1F200;

[1F101; 102; 103-1; 103-2; 104; 105; 106; 107; 108; 112; 118; 121; 123; 125; 133; 135; 136; 139;

|                                  |            |         |                         |
|----------------------------------|------------|---------|-------------------------|
| <b>Rated Assembly Inspection</b> | John Borns | Partial | Tuesday, April 23, 2013 |
|----------------------------------|------------|---------|-------------------------|

Partial Correction  
1 MISC

N&NE WALLS OF 1F150&1F151: OK TO APPLY 2ND LAYER OF GWB; GWB PERIMETER FIRE-CAULKED & APPROVED TO COVER

Partial Correction  
2 MISC

FOLLOWING TYPE (P) WALL SECTIONS OK TO TOP OUT (6') GWB ONE FACE FOR ADJACENT HVAC DUCT TO BE HUNG: ~24' OF 1F007 EAST WALL ACROSS FROM PASSENGER ELEVATORS; ~24' OF 1F100 NW WALL;

Partial Correction  
3 MISC

**RATED WALL DOG-LEGGED AT 1F151 WEST/NORTHWEST ONE**

LAYER 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL  
**INCLUDING E-W LEG AT TOP 24" WITH LID CONSTRUCTED TO  
CLOSE TO CONCRETE BEAM**

**Comments:**