



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122578, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rough Electrical Inspection - Commercial | John Borns | Passed | Wednesday, April 24, 2013 |

Comments: NO ISSUES FOUND ON PVC CONDUIT FOR FEEDER CABLE TO BE CAST INTO ROOF SLAB POUR.