



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130108, Building Permit - Commercial  
Address: 930 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Thursday, April 25, 2013

Corrective Action Required  
1 MISC

LS CODE OF ORDINANCES 17-309: DISPLAY OF "NO SMOKING" SIGN(S) REQUIRED AT PUBLIC ENTRY(IES). SHALL BE CONSPICUOUS AT EACH PUBLIC POINT OF ENTRY.

Corrective Action Required  
2 MISC

FINISH ELECTRICAL AT FRONT COUNTER SUBJECT TO APPROVAL WHEN COMPLETED

Corrective Action Required  
3 MISC

IBC 1210.1: SURFACE OF RESTROOM FLOOR MUST BE NON-ABSORBENT, SMOOTH. PROVIDE MANUFACTURER'S LITERATURE FOR VERIFICATION.

Corrective Action Required  
4 MISC

NEC 210-8; E3802.2: GFCI PROTECTION OF ELECTRICAL RECEPTACLES: DUPLEX ELECTRICAL RECEPTACLE AT CLOTHES WASHER NOT GFCI PROTECTED. IF NOT PROTECTED AND DESIGNATED AS "DEDICATED" FOR WASHER RECEPTACLE MUST BE SINGLE PLUG.

Corrective Action Required  
5 MISC

NEC 408.4: LABELING OF ELECTRICAL CIRCUIT POSITIONS AT PANEL(S): EACH BREAKER POSITION MUST BE CORRECTLY NUMBERED. ALSO CHECK CORRESPONDENCE WITH PANEL SCHEDULE.

Corrective Action Required  
6 MISC

IDENTIFICATION OF ELECTRICAL SERVICE PANELS: AFFIX

PERMANENT LABELS @ FACE OF PANEL FRONT PER DRAWINGS OR OCCUPANT PREFERENCE.

Corrective Action Required  
7 MISC

ROOFTOP INSPECTION:

- 1) NO SUITE # FOUND AT RTU
- 2) RTU ELECT RECEPT COVER NOT IN-USE TYPE
- 3) GAS PIPING SUPPORT BLOCKS
  - a) ADD 1 AT ONE N-S BRANCH
  - b) STACKED BLOCKS NOT ATTACHED
- 4) WIP ON PLUMBING VENT
- 6) CLEAR ALL DEBRIS OFF ROOF SURFACE AT SUITE FOOTPRINT

Corrective Action Required  
8 MISC

INSTALLATION OF LIGHTED SIGN SUBJECT TO APPROVAL WHEN INSTALLED. PER NEC 600-3: IF INTERNALLY LIGHTED MUST BE UL SHOP-LABELED PER 600.3. INSTALL NO NON-LISTED SIGN.

<b>Alarm Test</b>	Joe Dir	Passed	Thursday, April 25, 2013
<b>Sprinkler - Flow Test</b>	Joe Dir	Passed	Thursday, April 25, 2013
<b>Gas Piping Inspection - Commercial</b>	John Borns	Passed	Thursday, April 25, 2013
<b>Above Ceiling Inspection</b>	John Borns	Passed	Thursday, April 25, 2013
<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Thursday, April 25, 2013

**Comments: OK TO SET UP FOR BUSINESS; OK FOR CONTENTS ONLY. NO PUBLIC ENTRY, BUSINESS OPERATIONS, OR STAFF WORK PRIOR TO APPROVAL.**