



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Unit: 120, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|------------|----------|--------------------------|
| Rated Assembly Inspection | John Borns | Partial | Thursday, April 25, 2013 |

Partial Correction
1 MISC

N&NE WALLS OF 1F150&1F151: OK TO APPLY 2ND LAYER OF
GWB; GWB PERIMETER FIRE-CAULKED & APPROVED TO
COVER

Partial Correction
2 MISC

FOLLOWING TYPE (P) WALL SECTIONS OK TO TOP OUT (6')
GWB ONE FACE FOR ADJACENT HVAC DUCT TO BE HUNG: ~24'
OF 1F007 EAST WALL ACROSS FROM PASSENGER
ELEVATORS; ~24' OF 1F100 NW WALL;

Partial Correction
3 MISC

RATED WALL DOG-LEGGED AT 1F151 WEST/NORTHWEST ONE
LAYER 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL
INCLUDING E-W LEG AT TOP 24" WITH LID CONSTRUCTED TO
CLOSE TO CONCRETE BEAM

Partial Correction
4 MISC

**PER DESIGN REVISION, 1-HR RATED LID AT AF209A: FRAMING
AND 1" LINER BOARD OK TO PLACE ONE LAYER OF 5/8" TYPE X
GWB + TAPE AND MUD.**

Partial Correction
5 MISC

**OK TO COVER WHEN READY CORRIDOR CROSS-WALL AT DOOR
1F108 BOTH FACES 1ST LAYER 5/8" TYPE X GWB;**

Partial Correction
6 MISC

**OK TO TAPE & MUD WHEN READY SPACES 1F109 & 110 BOTH
FACES ONE LAYER 5/8" TYPE X GWB**

Comments: