

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20130263, Building Permit - Commercial

Address: 950 NW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Gas Service Inspection -

Commercial

John Borns

Passed

Friday, April 26, 2013

Gas Piping John Borns Failed Friday, April 26, 2013

Inspection - Commercial

Corrective Action Required

1 MISC WOOD BLOCK ROOFTOP PIPING SUPPORT:

- STACKED BLOCKS BE BE ATTACHED

- SLIP SHEETS REQUIRED; FASTEN TO SIDES OR TOPS OF

BLOCKS

Corrective Action Required

2 MISC IFGC 404.8: EXPOSED METALLIC PIPING MUST BE

PERMANENTLY PROTECTED WITH PAINT OR BY OTHER

APPROVED MEANS.

Comments: GAS PIPING PRESSURE TEST HELD STEADY AT >= 10 PSI FOR >=10 MIN. RELEASE GAS SERVICE.

ADDRESS IDENTIFICATION OF GAS SERVICE ENTRY: WHERE TWO OR MORE SERVICES ARE GROUPED HANG ADDRESS-STAMPED MEDALLIONS ON LOAD SIDE PIPE.