



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Unit: 120, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, April 29, 2013

Partial Correction
1 MISC

N&NE WALLS OF 1F150&1F151: OK TO APPLY 2ND LAYER OF
GWB; GWB PERIMETER FIRE-CAULKED & APPROVED TO
COVER

Partial Correction
2 MISC

FOLLOWING TYPE (P) WALL SECTIONS OK TO TOP OUT (6')
GWB ONE FACE FOR ADJACENT HVAC DUCT TO BE HUNG: ~24'
OF 1F007 EAST WALL ACROSS FROM PASSENGER
ELEVATORS; ~24' OF 1F100 NW WALL;

Partial Correction
3 MISC

RATED WALL DOG-LEGGED AT 1F151 WEST/NORTHWEST ONE
LAYER 5/8" TYPE X GWB OK TO TAPE, MUD, AND FIRE-SEAL
INCLUDING E-W LEG AT TOP 24" WITH LID CONSTRUCTED TO
CLOSE TO CONCRETE BEAM

Partial Correction
4 MISC

**PER DESIGN REVISION, 1-HR RATED LID AT 1F109A: FRAMING
+1" LINER BOARD + 1 LAYER OF 5/8" TYPE X GWB OK TO TAPE
AND MUD.**

Partial Correction
5 MISC

**CORRIDOR WALL AND CROSS-WALL AT DOOR 1F108 BOTH
FACES 2 LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD AND
FIRE-SEAL**

Partial Correction
6 MISC

OK TO TAPE & MUD WHEN READY SPACES 1F109 & 110 BOTH

FACES ONE LAYER 5/8" TYPE X GWB

Comments: