



**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

**220 SE GREEN ST.
P.O.BOX 1600**

**PHONE:
816-969-1200**

**FAX:
816-969-1201**

Certificate of Occupancy

Permit #: PRCOM20130108
Address: 930 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086
Inspected On: Tuesday, April 30, 2013
Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Full C of O	Tuesday, April 30, 2013

Comments:
ELECTRICAL RECEPTACLES AT FRONT COUNTER INACCESSIBLE FOR TEST.

**IBC 1210.1: SURFACE OF RESTROOM FLOOR MUST BE NON-ABSORBENT,
SMOOTH. MANUFACTURER'S LITERATURE FORTHCOMING FOR VERIFICATION.**