

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLAN REVIEW CONDITIONS

May 02, 2013

LYTLE CONSTRUCTION INC
1100 SE HAMBLER RD
LEES SUMMIT, MO 64081

Permit No: PRCOM20130740
Project Title: LEES SUMMIT MEDICAL CENTER NEUROLOGY SUITE
Project Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 60420990900000000
Location: HCA MIDWEST, LOTS 1A & 1B---LOT 1A
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: BUSINESS
Description: PHASED REMODEL

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Michael Weisenborn

Pending

1. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Expert from Sec. 7-130, Lees Summit Code of Ordinances.

Action required - Broadway Electrical does not have a current business license with the City of Lee's Summit. A licensed electrical contractor is required for permit approval.

Building Plan Review

Reviewed By: Michael Weisenborn

Rejected

1. 2005 NEC 517.13 - Grounding of receptacles and fixed electric equipment in patient care areas. Wiring in patient care areas shall comply with 517.13(A) and 517.13(B).

Action required - The only note on grounding that I can find refers to NEC 250. Make needed corrections.

2. ICC/ANSI A117.1 2003 404.2.3 - Maneuvering Clearance at Doors. Minimum maneuvering clearances at doors shall comply with Section 404.2.3 and shall include the full clear opening width of the doorway.

Action required - The required clear space from the pull side of door 200A and 202 is not provided. Make needed corrections.

Fire Plan Review**Reviewed By: Brian Austerman****Approved**

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Submit sprinkler plans for approval

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Submit alarm plans for approval

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.