



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130270, Building Permit - Commercial
Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, May 02, 2013

Partial Correction
1 MISC

OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X
GWB INSTALLATION AT 1 HR FIRE-RATED WALLS @
FOLLOWING LOCATIONS:

1ST FLOOR EXTERIOR WALLS:
ALL INCLUDING **SPACE 113 W WALL**

2ND FLOOR EXTERIOR WALLS:
S WALL E 52'; N WALL E 52'; E WALL N 21'; E WALL S 21'; **SPACE 204 W WALL**

Comments: