



**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20121405
Address: 178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Inspected On: Thursday, May 09, 2013
Inspected By: John Borns
Expiration Date: 5/23/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, May 09, 2013

Partial Correction:
1 MISC

RESOLVE ISSUES WITH FIRE DEPARTMENT AND WATER DEPARTMENT. eg, COMPLETE AND OBTAIN APPROVAL ON SPRINKLER F.P. PIPING AND BACKFLOW PREVENTION EQUIPMENT PIT WEST OF BULDING AND SPRINKLER F.P. PIPING AT SPRINKLER ROOM.

STATUS CHECK...

4/25/13: CENTURY PLMBG W/I/P AT WATER SVC @ REAR
4/26/13: CENTURY PLMBG W/I/P AT WATER SVC @ REAR
4/30/13: ROCK FILL TO GRADE IN AREA AROUND VAULT;
CONTRACTOR NOT ON SITE @ 16:00

Comments: