



**CITY OF LEE'S SUMMIT**  
**CODES ADMINISTRATION**

220 SE GREEN ST.  
P.O.BOX 1600

**PHONE:**  
816-969-1200

**FAX:**  
816-969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20121405  
**Address:** 178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081  
**Inspected On:** Thursday, May 09, 2013  
**Inspected By:** John BornsJohn Borns  
**Expiration Date:** 5/23/2013 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Thursday, May 09, 2013

Partial Correction:  
1 MISC

RESOLVE ISSUES WITH FIRE DEPARTMENT AND WATER DEPARTMENT. eg, COMPLETE AND OBTAIN APPROVAL ON SPRINKLER F.P. PIPING AND BACKFLOW PREVENTION EQUIPMENT PIT WEST OF BULDING AND SPRINKLER F.P. PIPING AT SPRINKLER ROOM.

**STATUS CHECK...**

4/25/13: CENTURY PLMBG W/I/P AT WATER SVC @ REAR  
4/26/13: CENTURY PLMBG W/I/P AT WATER SVC @ REAR  
4/30/13: ROCK FILL TO GRADE IN AREA AROUND VAULT;  
CONTRACTOR NOT ON SITE @ 16:00

<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Thursday, May 09, 2013
--	------------	------------------	---------------------------

Partial Correction:

1 MISC

RESOLVE ISSUES WITH FIRE DEPARTMENT eg, COMPLETE AND OBTAIN APPROVAL ON SPRINKLER F.P. PIPING AND BACKFLOW PREVENTION EQUIPMENT PIT WEST OF BUILDING AND SPRINKLER F.P. PIPING AT SPRINKLER ROOM.

STATUS CHECK...

4/25/13: CENTURY PLMBG W/I/P AT WATER SVC @ REAR

4/26/13: CENTURY PLMBG W/I/P AT WATER SVC @ REAR

4/30/13: ROCK FILL TO GRADE IN AREA AROUND VAULT;

CONTRACTOR NOT ON SITE @ 16:00

5/8/13: WU CLEAR PER BEN H. ADVISED ADAM @ DARLAND TO CONTACT J DIR TO GET FD CLEARED.

**Comments:**