



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20122702, Building Permit - Commercial
Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Partial	Friday, May 17, 2013

Partial Correction
1 MISC

SYSTEMS ABOVE BOTTOM CHORD OF ROOF/CEILING JOISTS OK TO CONCEAL WITH INSULATION IN FOLLOWING AREAS: 202; 204 & 207 AFTER ALL MC ELECT CABLE RUNS ARE SECURED WITHIN 12" OF ENTRY TO BOXES;

Partial Correction
2 MISC

SOFFIT FRAMING AND ABOVE-CEILING SYSTEMS OK TO COVER WHEN READY AT 1ST FLOOR EAST ENTRANCE AND 2ND FLOOR EAST VERANDA

Partial Correction
3 MISC

OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: PERIMETER OF 201;202; 203;206;207;208

Comments: