



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|------------|----------|-------------------------|
| Rated Assembly Inspection | John Borns | Partial | Wednesday, May 22, 2013 |

Partial Correction

1 MISC

1ST AND 2ND LAYER AT SOFFIT FROM 8 TO 9 LINE APPROVED

Partial Correction

2 MISC

OK TO COVER WHEN READY FIRE-BLOCKING OF WALL/FLOOR INTERSECTION AT EAST EXTERIOR ARC WALL BETWEEN COLUMN LINES (7) AND (12.9);

Partial Correction

3 MISC

OK TO COVER WHEN READY 2ND LAYER 5/8" TYPE X GWB AT WALL ON (19) FROM (C') TO (D') AT 5TH FLOOR. TAPE, MUD & FIRE-SEAL YET TO BE COMPLETED & APPROVED.

Comments: